

3465 Ourry Lane Abilene, TX 79606 325-695-1070

DATE: 4/5/2022

REPORT NO: 18478

To: Mr. Kent Strain
JH. Strain & Sons
P.O. Box 277

Tye, Texas 79563

Project: J.H. Strain & Sons
Quality Control Testing

REPORT ON: Determination of Atterberg Limits

TEST M ETHOD: ASTM D 4318

MATERIAL DESCRIPTION: Crushed Limestone Screenings

LOCATION SAM PLED: Knaus Pit

SAM PLED BY: Client

SAM PLE NUM BER: 22126

TESTED BY: Brendon Day

RESULTS:

Liquid Limit: 23

Plastic Limit: 15

Plasticity Index: 8

Notes:

This report contains the results of a test performed by Jacob & Martin, Ltd. on material sampled from the location indicated above.

The test does not constitute a geotechnical investigation.

COPIESTO: Above Jacob & Martin, Ltd.

Firm # F-2448

Barry W. Fowlkes, P.E.

Barry W. Foulkes, P.E.





DATE: 4/5/2022

REPORT NO: 18479

To: Mr. Kent Strain
JH. Strain & Sons

P.O. Box 277 Tye, Texas 79563 Project: JH. Strain & Sons

Quality Control Testing

REPORT ON: Decant Test for Aggregates

Test Methods: Tex-217-F, Part II and Tex-200-F

IDENTIFICATION: Sample Number 22126

Sampled by Client

DESCRIPTION: Crushed Limestone Screenings

Knaus Pit

TECHNICIAN: Client

RESULTS: Decant: 16.9%

REM ARKS:

COPIES TO: Above Jacob & Martin, Ltd. Firm # F-2448

Barry W. Fowlkes, P.E.

Barry W. Faulkes, P.E.





DATE: 4/5/2022

REPORT NO: 18489

To: Mr. Kent Strain

J.H. Strain & Sons P.O. Box 277 Tye, Texas 79563 Project: J.H. Strain & Sons

Quality Control Testing

COM PACTION TEST

Test Method: ASTM D 1557 Compaction Method: Method A


Preparation Method: Dry
Sampled By: Client
Sample Number: 22126
Sample Location Knaus Pit

Material Description: Crushed Limestone

Screenings

Rammer Type: Mechanical

Oversize Sieve: No. 4
Percent Oversize: 0
Specific Gravity 2.65
S.G. Method: Estimated



Results:

Maximum Dry Unit Weight (pcf): 123.6 Optimum Percent Moisture: 9

Barry W. Faulkes, P.E.

REM ARKS:

COPIESTO: Above

Jacob & Martin, Ltd. Firm # F-2448

Barry W. Fowlkes, P.E.





DATE: 4/5/2022

REPORT NO: 18511

To: Mr. Kent Strain
JH. Strain & Sons

P.O. Box 277 Tye, Texas 79563 Project: J.H. Strain & Sons

Quality Control Testing

REPORT ON: Sieve Analysis - Gradation

Test Method ASTM C-136

IDENTIFICATION: Sample Number 22126

Sampled by Client

DESCRIPTION: Crushed Limestone Screenings

Knaus Pit

TECHNICIAN: Steve Romero

RESULTS: Sieve Size: Percent Retained:

 3/8
 0

 #4
 1

 #8
 30

 #16
 51

 #50
 72

 #200
 83.4

REM ARKS:

COPIES TO: Jacob & Martin, Ltd.

Firm # F-2448

Barry W. Fowlkes, P.E.

Barry W. Faulkes, P.E.